

**RFP 490-18-04 Calhan Modular Building
Questions and Answers- September 26, 2018**

- 3.2. Studs: 3 5/8" metal stud framing- **Is wood acceptable? This will be more energy efficient, especially in Colorado.**
- Yes.
- 3.8. Insulation: R-13 faced fiberglass batts installed... **R-19 is needed per code with 2x6**
- Yes, R-19 is acceptable.
- 3.10. Siding: Manufacturer's standard vinyl or metal horizontal.... **Is metal vertical acceptable?**
- Yes, vertical metal is acceptable. Engineered wood siding is preferred.
- 3.14. Skirting: vinyl skirting with... **Is metal skirting acceptable?**
- If metal siding is used, metal skirting is acceptable. Engineered wood siding preferred.
- 4.1. Studs: 3 5/8" metal studs @ 16" oc.... **Is wood acceptable? This will be more energy efficient, especially in Colorado.**
- Yes.
- 6.6. Ceiling Height.... **Is 7' 10" acceptable?**
- Yes.

The spec calls out for fascia- Do you want an overhang?

- No overhang. This was in consideration of an entry way architectural feature.
- 11.1. Copper ASTM B88- **Please confirm they need to be copper**
- Copper is preferable, if the code allows alternate, that's acceptable.
- 12.2. Supply Ducts: Rigid foil faced fiberglass G90....**Is flex duct acceptable?**
- Yes.